



EYEWASH AND SAFETY SHOWERS

Where workers handle substances that could injure their eyes or get onto their bodies, eyewash stations or showers (or both) must be provided based on the hazard.

Requirements include the following:

- An unobstructed path; eyewash or shower accessible within 10 seconds.
- Installation meets manufacturer's requirements including criteria for water pressure, flow rate, and system testing.
- Water must flow for at least 15 minutes.
- Valves must remain open without the use of hands.
- Eyewash or shower stations must be clean, sanitary, and operating correctly; expired solutions must not be used in self-contained systems.



HAZARD ASSESSMENT

An eyewash or safety shower is considered a first-aid measure rather than a preventative one. A hazard assessment determines the hazards associated with a chemical and which first-aid measures are to be used in the event of an emergency. Factors to be evaluated in a hazard assessment include:

- Chemical properties: The physical state, concentration, pH (acids with a pH less than 2.5 and alkalis with a pH greater than 11.0 require immediate flushing to prevent damage), temperature, etc.
- Chemical-use patterns: How employees work with chemicals during handling, transfer, use, or disposal, including frequency and duration of use, and quantity of chemicals.
- Training: Evaluate training requirements based on hazard communication, material safety data sheets, and the measures employees can take to protect themselves, including personal protective equipment.
- Work-site conditions: Indoor or outdoor sites, protection from freezing conditions, fixed or non-fixed locations, and facility layout.
- Equipment: Availability of eyewash and body- flush equipment and water sources.

FOR ENQUIRIES:

YOUR SAFETY DEPARTMENT, LLC

P + 1 888 859 5653

info@yoursafetydept.com

www.yoursafetydept.com

© 2014-2021 **Your Safety Department, LLC**. All rights reserved. The information contained herein is provided "as is" and **Your Safety Department, LLC** does not warrant that it will be error-free or will meet any particular criteria of performance or quality. Do not quote or refer any information herein without **Your Safety Department, LLC**' prior consent. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



YOUR SAFETY Department

— SAFETY Solutions —

EQUIPMENT

Plumbed units are preferred where a clean water source is readily available. Self-contained units are effective where a water source is not readily available. Both must meet the general requirements.

- Eyewashes: Units must be provided in fixed work areas or stations when a hazard assessment or any other information indicates that an employee may reasonably be exposed to a substance that can cause corrosion or permanent tissue damage to the eyes.
- Safety showers: A shower is required at fixed work areas or stations when substantial areas of the worker's body may be exposed to large quantities of materials that are highly corrosive or highly toxic by skin absorption.
- Hand-held drench hoses: A single-headed emergency washing device connected to flexible hoses and used to irrigate and flush the face or other parts of the body.
- Solution/squeeze bottles: Chemical or isotonic solutions used as substitutes for water must be appropriate for the hazard, properly tested and maintained and replaced prior to the expiration date. They cannot be used as a sole means of protection nor a substitute for plumbed or self-contained equipment.
- Valve operation: Stay-open valves must be in place and be operable to allow an individual to use both hands to hold eyes open or remove clothing.
- Temperature: Water should be tepid. Temperature extremes can pose a health hazard to the worker. Elevated water temperatures may accelerate adverse chemical reactions.
- Water pressure and volume: In general, water pressure for plumbed eyewash should provide a water flow of at least 0.4 gallons, or 1.51 liters, per minute for 15 minutes. Self-contained eyewash units should meet the same flow-rate provision. Safety showers (plumbed and self-contained) should provide a flow rate of at least 20 gallons, or 76 liters, per minute with a minimum of 15 minutes under all operating conditions.
- Water quality: Only potable water should be used for eyewash and shower facilities. Improperly maintained plumbed or self-contained units can contaminate water reservoirs.
- Testing: All eyewash and shower facilities must be adequately maintained and should be activated weekly to flush the supply and line and to verify proper operations. Self-contained units should be maintained in accordance with the manufacturer's instructions. Particular attention must be given to flushing fluid and availability.
- Specific Requirement: If the chemical manufacturer requires specific decontaminates or procedures, you must provide them in addition to the eyewash or shower.

LOCATION OF EYEWASH AND/OR SHOWER

Generally, the distance from the worker's location to the device should not exceed 10 seconds walking distance. The determinant factor is immediate eye irrigation within 10 seconds.

The path must be unobstructed and cannot require opening doors or passing through obstacles unless other workers are always present to help the exposed worker. Locating the eyewash or shower outside the immediate source of exposure, where gases or highly volatile substances (e.g. anhydrous ammonia) are present, may be necessary.

DESIGN SPECIFICATIONS FOR EYEWASH AND/OR SHOWER

IDENTIFYING THE UNITS

The eyewash and safety shower facilities should be identified with a highly visible sign. The area around the facility should be well-lighted and highly visible. They must also be easily accessible and unobstructed.

TRAINING

Employees must be trained on the hazards associated with the material, the location of the eyewash and/or shower facilities, and the proper procedure for flushing the eyes and/or skin.



MINUTES OF MEETING

Date: _____ Person Conducting Meeting: _____

Topic: _____

Branch: _____ Division: _____

Attendees:

NAME	INITIAL	DATE

NAME	INITIAL	DATE

Additional Items Discussed:

Problem Areas or Concerns:

Comments:

FOR ENQUIRIES:

YOUR SAFETY DEPARTMENT, LLC

P + 1 888 859 5653

info@yoursafetydept.com

www.yoursafetydept.com

© 2014-2021 **Your Safety Department, LLC**. All rights reserved. The information contained herein is provided "as is" and **Your Safety Department, LLC** does not warrant that it will be error-free or will meet any particular criteria of performance or quality. Do not quote or refer any information herein without **Your Safety Department, LLC**' prior consent. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.